

Upes k/m
Zilokalnu k/m
Skolas k/m

APSTIPRINU:
P/A "Mālkalne" tehniskais
direktors: _____
2015.g. _____

Katlu mājas siltumnesēja turpgaitas grafiks 110 -70 °C

T āra gaisa temp.	t1 turpgaitas temp.	
8 - +2	77	
1	77	
0	77	
-1	78	
-2	79	
-3	79	
-4	80	
-5	81	
-6	83	
-7	84	
-8	86	
-9	88	
-10	91	
-11	93	
-12	95	
-13	97	
-14	100	
-15	102	
-16	104	
-17	106	
-18	108	
-19	109	
-20	110	